

**Bear Lake West POA**  
**Water Report**  
**February 2021**

Water usage for the last 30 days was 328K gallons, 173K on Plat-B and 155K on plat-C. These numbers reflect a 50K increase over last year, increased population and the excess water usage from #3 reservoir on Plat-B are the likely cause.

The excess water usage on #3 reservoir has been corrected, and is maintaining at a more normal level of usage. Most likely a leaky faucet or toilet, or maybe someone likes to leave the water dripping for their cat to drink, either way the usage is back to expected norms.

I replaced the radio control float on the #4 reservoir, and that seems to have taken care of the problems that we had been having with the pumping cycles on that reservoir. A new float was ordered to replace the one that was used of of parts stock.

February coliform test will be taken this week, results for January were good. Will take this years nitrate tests in March or April.

No other leaks or issues to report at this time.