

Bear Lake West POA Annual Meeting Water Report August 2022

For those of you who may not know me, I am Dan Fillion the BLW/POA Public Water system Operator. My job is to be sure that we are providing you with safe water to drink and to keep the system functioning so that you have water at the tap when you need it.

The BLW/POA 2021 Annual Consumer Confidence Report has been filed with the state of Idaho DEQ and is available online at www.bearlakewestpoa.com. Copies are available at this meeting and are posted at Cooper's Restaurant on the bulletin board and at our rural postal boxes as well as at the bulletin boards within the BLW/POA subdivision. If you want a printed copy please contact Dan Fillion at 208-945-1212 and he will get one for you. This is for Public Water System # 6040044 Bear Lake West POA

BLW/POA is currently up to date on all government mandated testing for our system.

BLW/POA water use for the last 12 months was 5.48 MG, this number is a decrease over last year and matches up well with numbers from 2017. Our largest water users seem to be cutting back on unnecessary irrigation and our system remains tight.

I am currently working on a project to increase the amount of solar power available to operate the pump control radios on the Plat-C reservoir as the current system lacks power during the colder/darker winter months.

I have been monitoring our main well levels and so far they are holding up through this period of drought, but I would really love to see some heavy snow falls this winter.

Your Water meter assembly is Property of the Water System, however keeping it accessible is the responsibility of the homeowner. You may want to become familiar with its location on your lot. Most meters and curb stops are marked with either a blue painted T-Post or re-bar, please do not remove the markers as they allow us to find your meter, not only to read it but also to shut the water off in the event of a broken pipe in your house to reduce flooding damage.

If you see a red light or red flashing light on one of our reservoirs please advise Dan Fillion as this may mean the the reservoir is low and may need servicing or repair. Call 208-945-1212.

Feel free to contact me with questions you may have about our water, or E-Mail me at df3315@aol.com. Thank you.