

## **Bear Lake West POA Annual Meeting 2021 Water System Report**

For new BLW/POA members, Daniel Fillion is the State certified Water System Operator for Bear lake West POA. His contact information is Phone# 208-945-1212 E-mail [def3315@aol.com](mailto:def3315@aol.com).

The 2020 BLW/POA Consumer Confidence Report for Public water system # 6060044 Bear Lake West POA is available at the POA web site [www.bearlakewestpoa.com](http://www.bearlakewestpoa.com) If you prefer a printed copy please contact Daniel Fillion at [def3315@aol.com](mailto:def3315@aol.com) or call 208-945-1212. Printed copies are also posted at Cooper's, at the POA mail boxes, and at bulletin boards on either Dutch Canyon Rd or Canyon Ridge Way in the POA.

Water usage for the last 12 months, end July to end July was 7.19 Million Gallons 3.14MG on the Plat-B well and 4.05MG on the Plat-C well. These number are a 500,000 thousand gallon increase over last years numbers. A combination of factors including increased full time population, drought issues and commercial use are driving the increase in usage.

We are up to date on all government mandated testing.

The Water System is functioning well and does not have any major leaks at this time. Age is beginning to be a factor as some portions of the system are 35 years old at this time.

The #3 and #4 water reservoirs on Plat-B will be cleaned and inspected later this fall.

I have had some recent questions about the systems viability, at present I do not see major problems in the near future. However Bear Lake West HOA has monitored a decrease in their main and secondary well levels over the past few years. We currently show 90 to 100 feet static well levels, in our two wells.

Please be aware that maintenance costs and replacement costs are currently at an all time high, so if we do encounter water system problems there will be costs involved.

Please feel free to contact me, Daniel Fillion at 202-945-1212 with questions or coments related to the water system, or any POA board member with other POA related issues.