

**Bear lake West POA**  
**Water Report**  
**April 2022**

Water usage for the last 30 days was 239K gallons, 116k on Plat-B and 123K on Plat-C. These numbers reflect a 19k gallon increase over the last two years. Increased full time population would be the most obvious reason, as no leaks or over pumping has been reported.

The automated pumping on Plat-B #4 reservoir has been put back in service, the float level was adjusted, and the radio battery was replaced.

Good news, I got a call from Kal Tucker at Maguire Iron, the company specializes in water tank refurbishment. Kal will visit BLW/POA in the next month or two and take a look at the issues we are having with the Plat-C reservoir. He is confident that Maguire Iron can remove the old lining and provide a new lining for the reservoir. When he has a bid ready I will send it to the board for approval and scheduling.

I have managed to put repair the bubbler gauges on both of our wells and am beginning to graph the well levels. At present plat-B well shows around 90 feet of water in the well, and Plat-C well Around 80 feet of water. I will track this thru the summer and keep you up to date to any changes in the levels.

April coliform test was taken on 4/4/22, waiting on the results. 2022 nitrate tests will go out in May. Fire hydrants will be flushed in the coming weeks once the weather warms a bit more.

Please keep me informed as to any new construction permits issued so I can get with the contractors for water meter installations.

No other major issues to report at this time.