

Bear Lake West POA
Water Report
June 2021

Water usage for the last 30 days was 531K gallons, 188K on the Plat-B well and 343K on Plat-C well. The numbers show an increase over the 5 year average. Some of the increase was due to a customer side leak at Jones on Mountain way which has been repaired, it also reflects hydrant flushing on Plat-B.

Plat-B hydrants were flushed just before Memorial day.

The check valve has been installed in the Plat-B well house outside faucet line.

The new well level gauge has just arrived for the Plat-B well house, will work on installing that as time permits.

The Plat-C well house drain line has been dug up and thrust blocked, and will be tested in the next few days to be sure it is properly fixed.

Waiting on excavation work at B-322 and B-238, to install new water services at these addresses.

Will install the meter assembly at the POA shop in the next week or so.

Got an E-mail from DR Pipeline, they are working on the quote for the Plat-C storage tank project and will get back with me when they have it done.

The 2021 CCR report has been prepared, waiting on the final draft from IRWA.

No other leaks or major issues to report at this time.