

**Bear Lake West POA**  
**Water Report**  
**July 2021**

Water usage for the last 30 days was, 1.63MG, 1.05MG on Plat-B and 625K gallons on Plat-C. These numbers are an increase over the past few years, the hot day weather and larger family groups staying multiple days along with increased irrigation of lawns and trees seem to be the main factors.

Water meter will be installed at B-322 when contractor excavates the curb stop.

Water meter has been installed at the POA maintenance shop.

Plat-B well cap was removed and well inspected to determine why the level gauge does not work. The 600 foot long air line was removed when the well pump was replaced. I will be working to remedy this issue in the coming days, parts on order.

The battery in plat-B reservoir #4 had to be replaced, unit is working well now.

The 2020 CCR report has been posted to the POA site and I will get some copies to post at Cooper's and POA bulletin boards and for the annual meeting.

Aquagauge system is holding its own for now, 1 of the laptops I use to graph the usage died, but I got several of them repaired last year so, just put another one on line to do the graphing, it is working well.

Dr Pipe company called and will be in the area soon to look at the Plat-C tank project and maybe the sewer line project too, if you haven't settled that issue yet.

Please keep me informed as to any new water hook ups that need to be done, as we now have only enough material to do 3 or 4. more parts are on order but have yet to show up.

Lead and copper tests have been delivered to the 10 homes where we test 3 have come back so far.

July coliform will go out on 7/12 or 7/19.

No other issues to report at this time.