

Bear Lake West POA
Water report
January 2022

Water usage for the last 30 days was 201K gallons, 65K on Plat-B and 136K on Plat-C. These numbers show a decrease on Plat-B usage and traditional usage on Plat-C. Again this is only the 3rd year for monthly numbers in winter so averages will take some time to be apparent.

January Coliform test will be taken on January 10th.

The aquagauge system continues to function but Long winter nights and cold temps do cause some telemetry drop outs, but for now I can at least get a fair idea of the tank level trends. Again this system should be fully replaced when POA has the funds to do so, along with adding deep well level monitors to the system. Expected cost \$20K

I will continue to try and get some estimates for the possible relining of the Plat-C reservoir. The inspection in 2020 showed degradation of the rubberized coating in the bottom of the tank. My best guess is around \$40K, but that is just a guess based on previous work done to the other tanks.

I am very glad to see a layer of snow finally to help insulate water meters and shallow service lines. No reported freeze ups yet.

No other major items or leaks to report at this time.