

**Bear Lake West POA**  
**Water Report**  
**October 2021**

Water usage for the last 30 days was 580K gallons, 245K on Plat-B and 335K on Plat-C. These numbers are a slight increase over recent years, The hot dry summer and increased full time population are the cause.

The October coliform test will go out on 10/18.

All lead and copper tests have been submitted, waiting on the results as I have to report those to the individual property owners and also submit a report to the State Health Dept.

Water meters have been read and bills will go out shortly.

Core & Main called and water meter installation supplies will be delivered this week. If all ordered parts show up we should have enough parts to do 10 new water hook ups.

Water meters have been installed at B-322 and C-422, waiting on excavation at C-397. No new meters will be installed after November 15<sup>th</sup>, until mid April 2022.

Still need to make repairs to the meter assembly at B-189, will wait till current run of bad weather passes as this is a small leak.

Will flush #3 & #4 reservoirs as time and weather permit.

The aquagauge system is working well, but I may need to replace a couple of the batteries as the weather gets colder because I am losing telemetry on long colder nights. These batteries run around \$75 each.

I have reminded DR. Pipeline that we need a bid to repair the Plat-C reservoir.

No other leaks or major issues to report at this time.