

**Bear Lake West POA**  
**Water Report**  
**July 2022**

Water usage for the last 30 days was 845K gallons, 393K on Plat-B and 452K on Plat-C. These numbers compare well with usage from the last 2 years and include usage from the 4<sup>th</sup> of July weekend. They are about 450K less than our highest recorded July use from a few years ago, when we had some over pumping problems.

B-272, good news the meter pit at this location has dried up so I do not believe the POA will need to dig this water service up at this time. I will continue to monitor this meter and advise if any changes.

The pump control batteries were replaced in the Plat-B #2 and #3 reservoirs in mid June.

The new/replacement main well pump and motor have arrived and are in the small maintenance shed.

I had a call from a homeowner who wanted to track their water usage, as I do not have access to the meter list or previous years information I referred the homeowner to Gary for their meter reading from last year.

Water service has been put in at B-300. Still waiting for other new construction sites to access their curb stops to install others. C-491 is a grandfathered meter so they just need to access the meter pit and hook it up. Please keep me advised as to any more new construction permits so I can keep track of inventory.

I received 4 new solar panels for the Plat-C reservoir power upgrade, need to order some additional pieces and supplies to complete the upgrade and installation.

No other major leaks or issues to report at this time.